



EDMUND G. BROWN JR.
GOVERNOR



MATTHEW RODRIGUEZ
SECRETARY FOR
ENVIRONMENTAL PROTECTION

State Water Resources Control Board

April 3, 2015

CERTIFIED MAIL
NO. 7014 2870 0001 3250 1083

Mr. Anthony Bianucci
Martinez Detention Facility
1000 Ward Street
Martinez, California 94553

**SUBJECT: FAILURE TO COMPLY; UNDERGROUND STORAGE TANK SYSTEMS AT
MARTINEZ DETENTION FACILITY, 1000 WARD STREET, MARTINEZ**

Dear Mr. Bianucci:

As of the date of this letter, the State Water Resources Control Board (State Water Board) has not received a complete response to our January 12, 2015 Notice of Violation (NOV)(attached). You are directed to correct the ongoing violations identified in the NOV and submit compliance documentation to the State Water Board and the Contra Costa County Health Services Department within ten (10) days from the date of this letter.

Please send all compliance documentation to the following:

State Water Board

Mr. Thomas Henderson
UST Enforcement Unit
State Water Resources Control Board
1001 I Street, 16th Floor
Sacramento, California 95814
tom.henderson@waterboards.ca.gov

Local CUPA

Ms. Alexandra McMullen
Supervising Administrative Support
Contra Costa County Health Services Department
4585 Pacheco Boulevard, Suite 100
Martinez, California 94553
alexandra.mcmullen@hsd.cccounty.us

Failure to comply with this notice may result in an enforcement action by the State Water Board. The State Water Board reserves the right to bring an action against the owner and/or operator of the tanks in violation, or it may recommend that the Contra Costa County Health Services pursue enforcement, or the Contra Costa County Health Services may elect to pursue enforcement independently.

Pursuant to Health and Safety Code, chapter 6.7, section 25299, the owner and operator of the tanks are liable for a penalty of \$500 to \$5,000 per tank, per day of violation. These penalties will continue to accrue until the violations have been corrected.

If you have any questions, please contact me by telephone at (916) 341-5551, or by email at Amantha.Henkel@waterboards.ca.gov.

Sincerely,



Amantha Henkel
Senior Environmental Scientist
UST Enforcement Unit
Office of Enforcement

Attachment: January 12, 2015 Notice of Violation

cc: *(via email only)*

Ms. Alexandra McMullen
Contra Costa County Health Services Department
alexandra.mcmullen@hsd.cccounty.us

Mr. Nick Umemoto
Contra Costa County Health Services Department
nick.umemoto@hsd.cccounty.us

Mr. Doug Parker
Contra Costa County Facilities Supervisor
dparker@gsd.cccounty.us



EDMUND G. BROWN JR.
GOVERNOR



MATTHEW RODRIGUEZ
SECRETARY FOR
ENVIRONMENTAL PROTECTION

State Water Resources Control Board

January 12, 2015

CERTIFIED MAIL
No. 7014 1200 0001 4195 1787

Mr. Anthony Bianucci
Martinez Detention Facility
1000 Ward Street
Martinez, California 94553

**SUBJECT: NOTICE OF VIOLATION; UNDERGROUND STORAGE TANK SYSTEM
LOCATED AT MARTINEZ DETENTION FACILITY, 1000 WARD STREET,
MARTINEZ**

Dear Mr. Bianucci:

As part of an initiative by the State Water Resources Control Board (State Water Board) to ensure compliance at government-owned and/or operated underground storage tank (UST) facilities in California, the State Water Board staff inspected the USTs at your facility on November 20, 2014, pursuant to authority under Health and Safety Code, chapter 6.7, section 25289.

The State Water Board has identified the following violations pursuant to Health and Safety Code (H&SC), chapter 6.7, and California Code of Regulations (CCR), title 23, chapter 16:

No.	Violation	Tank	Start Date	Stop Date	Regulation
1	Failure to Monitor Product Piping – Conventional suction system has unmonitored single-walled piping in tank sump. Approximately two gallons of diesel standing in piping sump.	Diesel	November 20, 2014	Ongoing	H&SC 25292(a)
2	Failure to Monitor Product Piping – Conventional suction system has unmonitored single-walled piping in transition sump.	Diesel	November 20, 2014	Ongoing	H&SC 25292(a)
3	Failure to Provide Monthly Designated Operator Reports – The Designated Operator reports for December 2013, January 2014, and October 2014 were not on-site at the time of inspection.	Diesel	January 1, 2014	Ongoing	23 CCR 2715(e)

FELICIA MARCUS, CHAIR | THOMAS HOWARD, EXECUTIVE DIRECTOR

1001 I Street, Sacramento, CA 95814 | Mailing Address: P.O. Box 100, Sacramento, Ca 95812-0100 | www.waterboards.ca.gov

No.	Violation	Tank	Start Date	Stop Date	Regulation
4	Failure to Perform Annual Monitoring Certification – An Annual Monitoring Certification was due by January 9, 2013; the certification was performed on February 11, 2013.	Diesel	January 10, 2013	February 11, 2013	23 CCR 2638(a)
5	Failure to Perform Spill Containment Test – A spill containment test was due by January 9, 2013. The test was performed on February 11, 2013.	Diesel	January 10, 2013	February 11, 2013	H&SC 25284.2
6	Failure to Perform Secondary Containment Testing – A secondary containment test was due by January 9, 2014. The test was performed on February 11, 2014.	Diesel	January 10, 2014	February 11, 2014	23 CCR 2637(a)

You are directed to correct the ongoing violations and submit compliance documentation to the State Water Board and Contra Costa County Health Services Department within sixty (60) days from the date of this letter. Have your Designated Operator make specific notations in the next monthly designated operator report indicating the ongoing violations have been corrected. The monthly designated operator report and any associated photos must be submitted as proof of compliance.

Please send all compliance documentation to the following:

State Water Board

Mr. Thomas Henderson
UST Enforcement Unit
State Water Resources Control Board
1001 I Street, 16th Floor
Sacramento, California 95814
thenderson@waterboards.ca.gov


Local CUPA

Ms. Alexandra McMullen
Supervising Administrative Support
Contra Costa County Health Services Department
4585 Pacheco Boulevard, Suite 100
Martinez, California 94553
alexandra.mcmullen@hsd.cccounty.us

Pursuant to Health and Safety Code, chapter 6.7, section 25299, the owner and operator of the tank(s) are liable for a penalty of \$500 to \$5,000 per tank, per day of violation. These penalties will continue to accrue until the violations have been corrected.

If you have any questions, please contact me by telephone at (916) 341-5551, or by email at amantha.henkel@waterboards.ca.gov.

Sincerely,



Amantha Henkel
Senior Environmental Scientist
UST Enforcement Unit
Office of Enforcement

cc: See next page.

cc: *(via email only)*

Ms. Alexandra McMullen
Contra Costa County Health Services Department
alexandra.mcmullen@hsd.cccounty.us

Mr. Nick Umemoto
Contra Costa County Health Services Department
nick.umemoto@hsd.cccounty.us

Mr. Doug Parker
Contra Costa County Facilities Supervisor
dparker@gsd.cccounty.us